Report for Dubra Gram Panchayat , Chakdah Block , Nadia District

Sl. No.	Attribute	
1.	Total Stand posts in Dubra Gram Panchayat	203 nos
2.	Total working stand posts in Dubra Gram Panchayat	180 nos
3.	Total Not working stand posts in Dubra Gram Panchayat	23 nos
4.	Total Valve in Dubra Gram Panchayat	37 nos
5.	Total sluice valve in Dubra Gram Panchayat	37 nos
6.	Total air valve in Dubra Gram Panchayat	0 nos
7.	Total scour valve in Dubra Gram Panchayat	0 nos
8.	Total water quality (Arsenic) tested in Chakdah Block	248 nos
9.	Total water quality (Iron) tested in Chakdah Block	251 nos
10.	Arsenic value > 0.05	116 nos
11.	Arsenic value <= 0.05	132 nos
12.	Iron value > 1	228 nos
13.	Iron value <= 1	23 nos
14.	Total Laboratoris in Chakdah Block	1 nos
15.	Total School in Dubra Gram Panchayat	24 nos